

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1249:105 Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: CADDX-CADDI Controls, Inc, 1420 North Main Street, Gladewater, TX 75647
Contact: *Carol Rucker (903) 845-6941 Ext 128 Fax (903) 845-6811

DESIGN: Models NX-4 and NX-6 combination household fire and burglary alarm control units. Refer to listee's printed data sheet for additional detailed product description and operational considerations. System components:

NX-4, NX-6	Control Unit
NX-124, NX-116, NX-108, NX-148	Keypad
EOL33, EOL68	End-of-line Resistors
NX-003	Enclosure
NX-508	Output Expander
NX-507	Relay Module
NX-148, NX-1308, NX-1316, NX-1324	Keypad

RATING: 120 VAC primary, 16.5 VAC secondary; 12 VDC standby

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm control unit for use with separately listed compatible initiating and indicating devices. The control unit can generate the three pulse temporal code pattern fire alarm signal (for total evacuation) as required per NFPA 72, 1996 Edition.

NOTE:

1. For household system, the **Fire Alarm Verification Feature** (delay of fire alarm signal) is NOT approving for use in California. This feature shall not be programmed into the control unit.
2. Burglary and other non-fire functions were not examined.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 16, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager